

# Great Lakes Water Quality Laboratory, Inc.

4/10/2023

**Email:**  
becky@greatlakeswaterlab.net

6461 Sunset Dr  
P O Box 131  
Lake Ann MI 49650

**Ph:** 231-275-7382  
**Fax:** 231-275-6510

**MI Dept. of Env. Quality Lab No:** 0091

## Laboratory Report

**For:** Onekama Township  
5435 Main St  
PO Box 458  
Onekama MI 49675  
231-889-3308

**Site:** Old Face Full  
13 Mi Rd at Lake Michigan  
Pierport MI 49675

**WSSN:**  
**County:** Manistee  
**Township:** Onekama

**Point of Collection:** drinking fountain

**District:** District Health Department #10

**Potable?** Y

**Well Number:**

**Lab ID:** 230323009

**Collected By:** B Blackmore  
**Date:** 03/24/2023  
**Time:** 1:00pm

**Received On:**  
**Date:** 03/23/2023  
**Time:** 2:30pm

**Reason for Test:**

<u>Date/Time Tested</u>	<u>Analyte</u>	<u>Test Result</u>	<u>Suggested Max Contaminant Level</u>	<u>Detection Limit</u>	<u>Units</u>
03/24/2023 01:30p	T Total Coliform	ABS	<1	0	CFU/100mL
03/24/2023 01:30p	E.coli E.coli	ABS	<1	0	CFU/100mL
ABS = Absent of Total Coliform and E Coli Analyst EW/BG					
03/24/2023 06:00a	N03 Nitrate	<1.0	10.0	1.00	mg/L
03/24/2023 06:00a	N02 Nitrite	<0.05	1.00	0.05	mg/L
Analyst BG					
04/07/2023 05:00p	Ca Calcium	37	250	10.00	mg/L
04/07/2023 05:30p	Mg Magnesium	8		5.00	mg/L
04/07/2023 06:00p	HDNS Hardness	125	50-250	10.00	mg/L
04/07/2023 06:00p	Fe Iron	0.1	0.3	0.10	mg/L
04/07/2023 04:00p	Na Sodium	2	250	1.00	mg/L
03/31/2023 12:00p	Cl- Chloride	<10	250	10.00	mg/L
03/31/2023 02:30p	F Fluoride	<0.2	4.0	0.20	mg/L
04/07/2023 12:30p	S04 Sulfate	16	250	10.00	mg/L
Analyst BG Data Entry JM					

ND = Not Detected; CR = Chlorine Residual

# Great Lakes Water Quality Laboratory, Inc.

4/10/2023

**Email:**  
becky@greatlakeswaterlab.net

6461 Sunset Dr  
P O Box 131  
Lake Ann MI 49650

**Ph:** 231-275-7382  
**Fax:** 231-275-6510

**MI Dept. of Env. Quality Lab No:** 0091

## Laboratory Report

**For:** Onekama Township  
5435 Main St  
PO Box 458  
Onekama MI 49675  
231-889-3308

**Site:** Old Face Full  
13 Mi Rd at Lake Michigan  
Pierport MI 49675

**WSSN:**  
**County:** Manistee  
**Township:** Onekama

**Point of Collection:** drinking fountain

**District:** District Health Department #10

**Potable?** Y

**Well Number:**

**Lab ID:** 230323009

**Collected By:** B Blackmore  
**Date:** 03/24/2023  
**Time:** 1:00pm

**Received On:**  
**Date:** 03/23/2023  
**Time:** 2:30pm

**Reason for Test:**

<u>Date/Time Tested</u>	<u>Analyte</u>	<u>Test Result</u>	<u>Suggested Max Contaminant Level</u>	<u>Detection Limit</u>	<u>Units</u>
<b>Sample Comments:</b> Bacteriological analysis SM9223 Nitrate analysis SM 4500 NO3-D Nitrite analysis SM 4500 NO2-B Fluoride analysis SM 4500 F-C Sulfate analysis SM 4500 SO4E Sodium Analysis SM 3113 B-Na					